


This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	Envent Engineering Ltd.	Manufacturer:	Envent Engineering Ltd.
Address:	7060 E Farrell Road S E Calgary, AB T2H 0T2	Address:	7060 E Farrell Road S E Calgary, AB T2H 0T2
Country:	Canada	Country:	Canada
Party Authorized To Apply Mark:	Same as Manufacturer		
Report Issuing Office:	Intertek Testing Services (ITS) Ltd, Edmonton, Alberta		

Control Number: 4002458

Authorized by: _____



for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Safety Requirements For Electrical Equipment For Measurement, Control, And Laboratory Use – Part 1: General Requirements [UL 61010-1:2012 Ed.3+R:29Apr2016]

Safety Requirements For Electrical Equipment For Measurement, Control, And Laboratory Use – Part 1: General Requirements (R2017) [CSA C22.2#61010-1-12:2012 Ed.3+U1;U2]

Safety Requirements For Electrical Equipment For Measurement, Control, And Laboratory Use - Part 2-201: Particular Requirements For Control Equipment [UL 61010-2-201:2014 Ed.1]

Safety Requirements For Electrical Equipment For Measurement, Control, And Laboratory Use - Part 2-201: Particular Requirements For Control Equipment [CSA/IEC 61010-2-201:2014 Ed.1]

Intrinsically Safe And Non-Incendive Equipment For Use In Hazardous Locations (R2016) [CSA C22.2#157:1992 Ed.3+G1;U2]

Standard(s): Nonincendive Electrical Equipment For Use In Class I And II, Division 2 And Class III, Divisions 1 And 2

Standard(s):	<p>Nonincendive Electrical Equipment For Use In Class I And II, Division 2 And Class III, Divisions 1 And 2 Hazardous (Classified) Locations [CSA C22.2#213:2017 Ed.3+U1;U2;U3]</p> <p>Explosion-Proof Enclosures For Use In Class I Hazardous Locations (R2016) [CSA C22.2#30:2020 Ed.4]</p> <p>ISA 12.27.01 Issued: 2011/01/01 Requirements for Process Sealing Between Electrical Systems and Flammable or Combustible Process Fluids</p> <p>UL 913 Issue:2006 Ed.7+R:23-Sep-2011 Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division I, Hazardous (Classified) Locations</p> <p>Nonincendive Electrical Equipment For Use In Class I And II, Division 2 And Class III, Divisions 1 And 2 Hazardous (Classified) Locations [UL 121201:2017 Ed.9+R:01Apr2021]</p> <p>Standard For Explosion-Proof And Dust-Ignition-Proof Electrical Equipment For Use In Hazardous (Classified) Locations [UL 1203:2013 Ed.5+R:05Apr2022]</p>
Product:	<p>Class I Division 1 Groups BCD or CD models 330 series, H2S Analyzer and Total Sulphur Analyzer</p> <p>Class I Division 2 models 331 series; H2S Analyzer; Class I, Division 2, Groups A, B, C and D and Total Sulphur Analyzer; Class I, Division 2, Groups B, C and D.</p> <p>Temperature code (all models): T3C</p> <p>Ambient Temperature Range (all models): 0°C to 50°C</p>
Models:	<p>330 or 331; may be followed by S or SDS.</p>